

NOTES:

- 1. GRAVEL BEDDING MAY BE USED IN PLACE OF CONCRETE IN NON-TRAFFIC AREA AT DISCRETION OF ENGINEER.
- 2. MACHINE SEATING SURFACES ON BOTH COVER & FRAME.
- 3. ALL CASTINGS TO BE DIPPED IN ASPHALTIC PAINT AFTER MACHINING
- 4. TOLERANCE TO BE ±0.125" FOR ALL DIMENSIONS.
- 5. CASTING TO BE SHOT BLASTED.
- 6. CASTINGS TO BE ASTM A48 CLASS 35B.

DATE: 03/07	CITY OF NORFOLK — DEPARTMENT OF UTILITIES STANDARD DETAILS	SCALE: NOT TO SCALE
	AIR VENT / BLOW-OFF VALVE	DRAWING NO. CWS 03